

Attestation

Italian CAM

On the 5th of November 2024, Eurofins Product Testing A/S received a sample of a wood based panel with the product name:

Melamine faced particleboard

supplied by

CLEAF SpA

The emissions were tested according to the Italian CAM Decree DM 23 Giugno 2022 n. 254, GURI n. 183 del 6 agosto 2022 section 2.5.1. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2024-00518002_B_EN).


Evaluation of the emission test result according to Italian CAM criteria:

- The relevant CMR compounds were not detectable after 28 days.
 - The sum of VOC ("TVOC") after 28 days was in compliance with the limit of $\leq 1500 \text{ mg/m}^3$.
 - Formaldehyde after 28 days was in compliance with the limit of $< 60 \text{ }\mu\text{g/m}^3$.
 - Acetaldehyde after 28 days was in compliance with the limit of $< 300 \text{ }\mu\text{g/m}^3$.
 - Toluene after 28 days was in compliance with the limit of $< 450 \text{ }\mu\text{g/m}^3$.
 - Tetrachloroethylene after 28 days was in compliance with the limit of $< 350 \text{ }\mu\text{g/m}^3$.
 - Xylene after 28 days was in compliance with the limit of $< 300 \text{ }\mu\text{g/m}^3$.
 - 1,2,4-Trimethylbenzene after 28 days was in compliance with the limit of $< 15000 \text{ }\mu\text{g/m}^3$.
 - 1,4-Dichlorobenzene after 28 days was in compliance with the limit of $< 90 \text{ }\mu\text{g/m}^3$.
 - Ethylbenzene after 28 days was in compliance with the limit of $< 1000 \text{ }\mu\text{g/m}^3$.
 - 2-Butoxyethanol after 28 days was in compliance with the limit of $< 1500 \text{ }\mu\text{g/m}^3$.
 - Styrene after 28 days was in compliance with the limit of $< 350 \text{ }\mu\text{g/m}^3$.
-

30 January 2025



Rasmus Verdier
Analytical Service Manager



Mads Folkjær
Analytical Chemist