

Attestation

Italian CAM

On the 21st of January 2026, Eurofins Product Testing A/S received a sample of a wood-based panel with the product name:

One side melamine faced thin MDF panel

supplied by

CLEAF SpA

The emissions were tested according to the Italian CAM Decree DM 23 Giugno 2022 n. 254, GURI n. 184 del 8 agosto 2022. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2026-00037706_A_EN).

Evaluation of the emission test result according to Italian CAM:

- The relevant CMR compounds were not detectable after 28 days.
 - The sum of VOC ("TVOC") after 28 days was below the limit of 500 µg/m³.
 - Formaldehyde after 28 days was below the limit of 60 µg/m³.
 - All other parameters were below their respective limit values after 28 days.
-

14 April 2026



Claus Bonde
Analytical Service Manager