

# Attestation

## Italian CAM

On the 21<sup>st</sup> of January 2026, Eurofins Product Testing A/S received a sample of a wood-based panel with the product name:

### **SAFIRE Flame retardent melamine faced particle b**

supplied by

**CLEAF SpA**

The emissions were tested according to the Italian CAM Decree DM 23 Giugno 2022 n. 254, GURI n. 184 del 8 agosto 2022. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2026-00037703\_A\_EN).

#### **Evaluation of the emission test result according to Italian CAM:**


---

- The relevant CMR compounds were not detectable after 28 days.
  - The sum of VOC ("TVOC") after 28 days was below the limit of 500 µg/m<sup>3</sup>.
  - Formaldehyde after 28 days was below the limit of 60 µg/m<sup>3</sup>.
  - All other parameters were below their respective limit values after 28 days.
- 

14 April 2026



Isabella B. Larsen  
Analytical Service Manager



Claus Bonde  
Analytical Service Manager