

# Attestation

## Italian CAM

On the 21<sup>st</sup> of January 2026, Eurofins Product Testing A/S received a sample of a wood-based panel with the product name:

### Melamine faced MDF

supplied by

### CLEAF SpA

The emissions were tested according to the Italian CAM Decreto Ministeriale 24 novembre 2025 – Criteri Ambientali Minimi per l'edilizia. Sampling, testing, and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, and ISO 16000-11 (see the test report no. 392-2026-00377404\_B\_EN).

#### **Evaluation of the emission test result according to Italian CAM:**

---

- The relevant CMR compounds were not detectable after 28 days.
  - The sum of VOC ("TVOC") after 28 days was in compliance with the limit of < 1000 µg/m<sup>3</sup>.
  - Formaldehyde after 28 days was in compliance with the limit of < 60 µg/m<sup>3</sup>.
  - Acetaldehyde after 28 days was in compliance with the limit of < 200 µg/m<sup>3</sup>.
  - Toluene after 28 days was in compliance with the limit of < 300 µg/m<sup>3</sup>.
  - Tetrachloroethylene after 28 days was in compliance with the limit of < 250 µg/m<sup>3</sup>.
  - Ethylbenzene after 28 days was in compliance with the limit of < 750 µg/m<sup>3</sup>.
  - Xylene after 28 days was in compliance with the limit of < 300 µg/m<sup>3</sup>.
  - Styrene after 28 days was in compliance with the limit of < 250 µg/m<sup>3</sup>.
  - 2-Butoxyethanol after 28 days was in compliance with the limit of < 1500 µg/m<sup>3</sup>.
  - 1,2,4-Trimethylbenzene after 28 days was in compliance with the limit of < 1000 µg/m<sup>3</sup>.
  - 1,4-Dichlorobenzene after 28 days was in compliance with the limit of < 60 µg/m<sup>3</sup>.
- 

18 March 2026



Isabella B. Larsen  
Analytical Service Manager



Claus Bonde  
Analytical Service Manager