

# Attestation

## Italian CAM

On the 21<sup>st</sup> of January 2026, Eurofins Product Testing A/S received a sample of a wood-based panel with the product name:

### Melamine faced particle board P2

supplied by

### CLEAF SpA

The emissions were tested according to the Italian CAM Decreto Ministeriale 24 novembre 2025 – Criteri Ambientali Minimi per l'edilizia. Sampling, testing, and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2026-00037702\_A\_EN).

#### Evaluation of the emission test result according to Italian CAM Premium Score:

- The relevant CMR compounds were not detectable after 28 days.
- The sum of VOC ("TVOC") after 28 days was compliance with the limit of < 500 µg/m<sup>3</sup>.
- Formaldehyde after 28 days was compliance with the limit of < 10 µg/m<sup>3</sup>.
- Acetaldehyde after 28 days was compliance with the limit of < 100 µg/m<sup>3</sup>.
- Toluene after 28 days was compliance with the limit of < 150 µg/m<sup>3</sup>.
- Tetrachloroethylene after 28 days was compliance with the limit of < 120 µg/m<sup>3</sup>.
- Ethylbenzene after 28 days was compliance with the limit of < 350 µg/m<sup>3</sup>.
- Xylene after 28 days was compliance with the limit of < 100 µg/m<sup>3</sup>.
- Styrene after 28 days was compliance with the limit of < 120 µg/m<sup>3</sup>.
- 2-Butoxyethanol after 28 days was compliance with the limit of < 1000 µg/m<sup>3</sup>.
- 1,2,4-Trimethylbenzene after 28 days was compliance with the limit of < 500 µg/m<sup>3</sup>.
- 1,4-Dichlorobenzene after 28 days was compliance with the limit of < 30 µg/m<sup>3</sup>.

18 March 2026



Isabella B. Larsen  
Analytical Service Manager



Claus Bonde  
Analytical Service Manager